

# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY, Salem.

To Vaigai Public School INVOICE No.: 7143  
 196, Salem to Chennai NH Road, Muthampatty (Po)  
 Valapady (Tk), Salem (313111). Date: 24.6.24  
 Ref.: Your Lr No.: ..... Date: 24.6.24

Sl. No.	DESCRIPTION	No. of Samples	Rate Rs.	Amount Rs.	Ps.
	Towards the analysis charges of water sample / Alum / Bleaching Powder <u>Sample No.:</u> 59803-59804 GST - 18/- DD No. 294705, SBI Salem. RS. 1652/- Dt. 24.6.24	1	1400	1400 252 /	

Rupees One thousand Six hundred and fifty two Only.

Note:

Please make it convenient to collect water sample test report within 15 days from the date of submission. Test report will be given only on Paying water testing charges in the form of Demand Draft in favour of The Executive Engineer, TWAD Board, RWS Division, Salem.

**Junior Water Analyst / TWAD Board**  
 District Water Testing Laboratory  
 Salem.

*Chubares*  
**PRINCIPAL,**  
**VAIGAI PUBLIC SCHOOL,**  
 196, Salem to Chennai NH Road,  
 Muthampatty (Po), Valapady (Tk),  
 Salem (Dt)- 636 111.

*Mr. Agayag*  
**CORRESPONDENT,**  
**VAIGAI PUBLIC SCHOOL,**  
 196, Salem to Chennai NH Road,  
 Muthampatty (Po), Valapady (Tk),  
 Salem (Dt)- 636 111.



**TEST REPORT**

Sample Receipt No/Date :	59803-59804/Dt.24.06.2024
Invoice Details :	7143/Dt.24.06.2024
Customer Name and Address :	The Principal , Vaigai Public School,196, salem main road, Muthampatty Po, Valapady Tk,Salem-636 111.
Test Commenced on :	24.06.2024
Test Completed on :	25.06.2024
Test Report Date :	26.06.2024


**SAMPLE DETAILS FURNISHED BY CUSTOMER**

Source :	RO Water.
Location :	RO Water @ Vaigai Public School .Valapady.
Sample drawn by/Date :	Customer/Dt.24.06.2024
Quantity Received :	2 litres
Sample Container :	Plastic
Condition of the Sample :	Good Condition

The test result of sample received is as follows.


S.No	I. CHEMICAL EXAMINATION	Method of Testing	Unit	Sample No.	Specification as per IS 10500 : 2012
				59803 Result	Permissible Limit
1	pH at 25°C	IS 3025 Part 11-1983	-	6.55	6.5-8.5
2	Total Alkalinity as CaCO <sub>3</sub>	IS 3025-Part 23-1986	mg/L	36	600
3	Total Hardness as CaCO <sub>3</sub>	IS 3025 Part 21-2009	mg/L	36	600
4	Chloride as Cl	IS 3025-Part 32-1988	mg/L	18	1000
5	Sulphate as SO <sub>4</sub>	IS 3025-Part 24-1986	mg/L	5	400
6	Nitrate as NO <sub>3</sub>	APHA 23rd Edition 2017- 4500 -NO2 B	mg/L	0	45
7	Fluoride as F	APHA 23rd Edition 2017 – 4500- F-D	mg/L	0.2	1.5


.....End of the report.....

  
 Authorised Signatory,  
 TWAD Board, R.W.S,  
 Salem.

**Note:**

1. The test results relate only to the tested sample.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

  
**PRINCIPAL,**  
**VAIGAI PUBLIC SCHOOL,**  
 196, Salem to Chennai NH Road,  
 Muthampatty (Po), Valapady (TK),  
 Salem (Dt)- 636 111

  
**CORRESPONDENT,**  
**VAIGAI PUBLIC SCHOOL,**  
 196, Salem to Chennai NH Road,  
 Muthampatty (Po), Valapady (TK),  
 Salem (Dt)- 636 111



## TEST REPORT

Sample Receipt No/Date :	59803-59804/Dt.24.06.2024
Invoice Details :	7143/Dt.24.06.2024
Customer Name and Address :	The Principal , Vaigai Public School,196, salem main road, Muthampatty Po, Valapady Tk,Salem-636 111.
Test Commenced on :	24.06.2024
Test Completed on :	25.06.2024
Test Report Date :	26.06.2024
<b>SAMPLE DETAILS FURNISHED BY CUSTOMER</b>	
Source :	RO Water.
Location :	RO Water @ Vaigai Public School ,Valapady.
Sample drawn by/Date :	Customer/Dt.24.06.2024
Quantity Received :	2 litres
Sample Container :	Plastic
Condition of the Sample :	Good Condition
Appearance, Colour, Odour :	Clear/Colourless/Agreeable.

The test result of sample received is as follows.

S.No	<u>I. Physical Examination</u>	Method of Testing	Unit	Sample No. 59803 Result	Specification as per IS 10500 : 2012 Permissible Limit
8	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	5
9	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	98	2000
10	Electrical Conductivity	APHA 23 <sup>rd</sup> Edition 2017 - 2510 B	µS/cm	140	-
	<u>II. Chemical Examination</u>				
11	Ph. Alkalinity as CaCO <sub>3</sub>	IS 3025-Part 23-1983	mg/L	0	-
12	Calcium as Ca	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	8	200
13	Magnesium as Mg	APHA 23rd Edition 2017 - 3500 Mg B	mg/L	4	100
14	Sodium as Na	APHA 23rd Edition 2017 - 3500 Na B	mg/L	-	-
15	Potassium as K	APHA 23rd Edition 2017 - 3500 K B	mg/L	-	-
16	Iron as Fe	APHA 23rd Edition 2017 - 3500 Fe B	mg/L	0.00	1
17	Manganese as Mn	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	0.00	0.3
18	Free Ammonia as NH <sub>3</sub>	APIA 17th Edition-1989- 4500 NH3C	mg/L	0.00	0.5
19	Nitrite as NO <sub>2</sub>	APHA 23rd Edition 2017- 4500-NO3 B	mg/L	0.00	-
20	Phosphate as PO <sub>4</sub>	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0.00	-
21	Free residual chlorine	BIS 10500:2012	mg/L	0.00	-
	<u>III. Bacteriological Examination</u>			59804	
22	Feecal Coliform per 100 ml	IS/APHA	CFU	0	0

.End of the report.....

Authorised Signatory,  
 TWAD Board, R.W.S.,  
 Salem.

CORRESPONDENT,  
 VAIGAI PUBLIC SCHOOL,  
 196, Salem to Chennai NH Road,  
 Muthampatty (Po), Valapady (Tk),  
 Salem (Dt)- 636 111.

Note:

**PRINCIPAL,**  
**VAIGAI PUBLIC SCHOOL,**  
 196, Salem to Chennai NH Road,  
 Muthampatty (Po), Valapady (Tk),  
 Salem (Dt)- 636 111.



**GOVERNMENT OF TAMIL NADU**  
**DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE**  
**SANITARY CERTIFICATE**

YEAR 2024-2025

**APPENDIX-3**

(Chapter III Rule:24)

Tamil Nadu Educational Rules

L.Ds.No. 1572 /E2/2024. Dt: 09.07.2024 Office of The District Health Officer

Health Services, Attur - HUD.

I hereby declare that I have inspected The **VAIGAI PUBLIC SCHOOL, 196, SALEM TO CHENNAI NH ROAD, MUTHAMPATTI (PO), VALAPADI (TK), ATTUR (HUD), SALEM (DT)** Building and premises on the day of **09.07.2024** and certify that the accommodation provided for each of the several classes is sufficient for the maximum number of students studying therein and is properly ventilated and lighted;

- : the building is maintained in substantial repair;
- : the building is neat and clean;
- : the latrine arrangements are adequate and satisfactory;
- : the supply of drinking water is wholesome;
- : the sanitation is good in all other necessary aspects; and
- : the necessary laboratory safety measure activity is satisfactory.


that there is no sources of mosquito breeding in the campus. If found *Aggry*

*Aggry*  
**CORRESPONDENT,**  
**VAIGAI PUBLIC SCHOOL,**  
**196, Salem to Chennai NH Road,**  
**Muthampatty (Po), Valapady (Tk),**  
**Salem (Dt)- 636 111.**

later this certificate will be automatically stands cancelled.

The certificate is issued with the condition enclosed.

: This certificate is valid for the **ONE YEAR** only.



District Health Officer,  
 Attur Health Unit District,

Salem Principal,

VAIGAI PUBLIC SCHOOL,  
 196, Salem to Chennai NH Road,  
 Muthampatty (Po), Valapady (Tk),  
 Salem (Dt)- 636 111.

*Seal translated in English*

District Health Office

Attur

09.July.2024

Counter Signed:

Signature: 09 JUL 2024



*Aggry*  
**C. VEERAMUTHU, B.A.B.L**  
**ADVOCATE & NOTARY PUBLIC**  
**(GOVT OF INDIA)**  
**Opp-Sub Registrar Office**  
**Valappady, Salem-636 115**  
**Cell: 98426 27754**

**Certificate is issued subject to the following conditions:**

- 1) The Garbage generated within the premises should be collected and disposed off properly by appointing required sanitary staff.
- 2) On any account, the Garbage should not be burnt.
- 3) The employees should be educated to prevent the usage of plastics in the premises and no one should bring plastic carry bags, use and throw Tumblers to the premises.
- 4) To ensure that no mosquitogenic environment in the campus under section 83 of TNPH Act, 1939.
- 5) N.O.C. (or) License for Building to be obtained under TNPH Act 1939 and Buildings Act 1965.
- 6) Fire Precautionary measures, and First Aid box, should be provided in the campus.
- 7) Sign Board regarding 'No Smoking Zone', 'Here Smoking and Spitting is an offence' should be exhibited in front of the premise
- 8) This Certificate issued is liable to be cancelled at any time on infringement if any of the above said conditions and for improper maintenance of sanitation, improper maintenance of the building as well as toilets in the premises.
- 9) This certificate should be **renewed every year.**



**PRINCIPAL,**  
**VAIGAI PUBLIC SCHOOL,**  
196, Salem to Chennai NH Road,  
Muthampatty (Po), Valapady (Tk),  
Salem (Dt)- 636 111.



**CORRESPONDENT,**  
**VAIGAI PUBLIC SCHOOL,**  
196, Salem to Chennai NH Road,  
Muthampatty (Po), Valapady (Tk),  
Salem (Dt)- 636 111.